


M E M O R A N D U M

TO: EA Personnel July 8, 1992  
FROM: J. S. Miller EA-EM-92-1371  
SUBJECT: Papers To Be Presented at ASME 1992 Winter Annual Meeting

Attached for your information are the matted papers that will be presented at the 1992 ASME Winter Meeting and Fifth International Topical Meeting on Nuclear Thermal Hydraulics. These papers are:

1. J. S. Miller, "Developing Engineering Analysis Capabilities at a Nuclear Utility", 1992 ASME Winter Meeting, (November 1992).
2. J. L. Burton and J. S. Miller, "PRA Development and Uses", 1992 ASME Winter Meeting, (November 1992).
3. John Lynch at Eric Ballon, "Postulated Effects of a Loss of Spent Fuel Pool Cooling at a Nuclear Power Plant", 1992 ASME Winter Meeting, (November 1992).
4. G. J. Gitnick, ? , "BWRSC: An On-Line Stability Exclusive Region Calculation For BWR's", Fifth International Topical Meeting on Nuclear Reactor Thermal Hydraulics, Salt Lake City, (September 1992).

If you have any questions, please see me or the other authors.

  
\_\_\_\_\_  
J. S. Miller  
Director  
Engineering Analysis

JSM/mg  
cc: B. J. Gitnick  
E. L. Ballon

# PRA DEVELOPMENT AND USES

by

J. L. Burton  
J. S. Miller

Gulf States Utilities  
River Bend Nuclear Group

## ABSTRACT

Beginning in 1987, the Gulf States Utilities (GSU) Engineering Analysis staff at River Bend Station (RBS) has been using Probabilistic Risk Assessment (PRA) methods to provide upper management, nuclear licensing and the nuclear plant staff an indication of the safety significance for daily plant situations. PRA methods provide excellent means of evaluating the safety significance of failed components, human interactions, maintenance activities and the impact of design and/or construction changes.

The first segment of the PRA (i.e., Level 1 PRA) is usually referred to as the Probabilistic Safety Analysis (PSA). The PSA's performed at RBS consist of addressing the safety significance for several Nuclear Regulatory Commission (NRC) issues, major modifications to the nuclear plant, nuclear licensing issues and plant operation and Technical Specification issues.

For example, in one case a safety analysis on fire risk was performed. The results of this evaluation showed that the potential safety significance of a NRC concern identified at the plant was very low. In another case, a preferred transformer failed just prior to the end of a refueling outage. Operation of the transformer was not required to comply with the Technical Specifications. However, a PSA on starting up without the transformer in place showed there was a significant impact on the safety margin of the nuclear plant. In addition, actual operator consequences were demonstrated to be significant. Therefore the plant start-up was delayed several days while a replacement transformer was installed.

Although some safety analyses using evaluations may cause the utility a delay in start-up or limit operations, the long term effects of PSA integration into day to day decisions made at the plant will save the utility significant resources during the life of the plant and provide assurances that the plant remains safe and reliable.

## INTRODUCTION

After the Three Mile Island-2 (TMI-2) accident in 1979, severe accident issues have influenced Nuclear Regulatory Commission (NRC) thinking in regulating nuclear power station construction, design operation, and maintenance activities. Subsequent to the TMI-2 accident, the NRC formulated a Severe Accident Policy.

The Severe Accident Policy is a guide to regulatory decision-making. The policy provides general procedures for staff approval of items related to severe accidents. Even though the NRC has stated that it believes existing nuclear power plants pose no undue risk to the health and safety of the public, the Severe Accident Policy statement indicates that all plants will be required to perform a probabilistic safety analysis (PSA) to verify that this conclusion is true and to identify any potential outliers or plant vulnerabilities that might be plant specific. The NRC had recognized the value of PSA in assuring the safety of plant design and assuring the safety of plant design and operation. Plant specific safety evaluations can be accomplished through the use of Probabilistic Risk Assessment (PRA) methods.

A full scope PRA is composed of three segments. The first segment is the Level I PRA and is considered a PSA leading to the determination of core damage frequency (CDF). The CDF provides a number which represents how often the reactor core can be damaged per reactor year of operation. For example, a CDF equal to  $10^{-6}$  means that the reactor core could be damaged once in every million years. The CDF provides analytical evidence based on important initiating events (e.g., loss of coolant accidents (LOCAs) and potential transients) and the availability of equipment important to mitigating core damage. The second segment of the PRA is the Level II PRA which provides analytical evidence to the containment failure probability, which may or may not require reactor vessel melt through. The third segment of the PRA is the offsite consequences to the general public subsequent to

the failure of the containment. The PRA method of analysis is the most practical way of quantifying nuclear reactor safety with respect to the use and operation of procedures and equipment to mitigate the consequences of a severe accident.

To introduce these techniques into risk evaluations at operating plants, the NRC issued Generic Letter (GL) 88-20 requiring plants to perform Individual Plant Examinations (IPEs) for severe accident vulnerabilities. The initial GL and Supplements 1, 2, and 3 are concerned with the Level I and II PRAs, and address internal events. Supplement 4 incorporates fires, seismic events, floods, weather related events, etc. into the Level I and II results to create an IPE for external events (IPEEE).

For Gulf States Utilities' (GSU) River Bend Station (RBS), a focused Level I PRA<sup>1</sup> was begun in 1987, in anticipation of the issuance of GL 88-20. The Level II PRA followed in 1990. These portions of the Generic Letter submittal are due in October 1992. The IPEEE began in April 1992, with an EPRI tailored collaboration on the fire PRA. This was during the plant's fourth refueling outage, which allowed access to various areas for fire and seismic walkdowns. The IPEEE submittal is due to NRC in June 1994.

## DESCRIPTION OF PRA METHODS

GSU believes emphasis should be placed on mitigating core damage, therefore the figure of merit used in assessing safety significance is CDF. This can be determined by using the results of the PSA (i.e., Level I PRA). The PSA is comprised of an extremely detailed model of 23 major systems that are important to plant safety with a large number of these systems modeled to the component level. The modeling methodology employed by GSU is documented in Reference 2. An example of typical sequence model is shown in Figure 1. The sequence model is composed of event trees which identify the initiating events and systems called upon to mitigate the consequences of the event. As seen in Figure 1, the event can progress depending on the availability of mitigating systems to an "OK" status (i.e., no core damage) or to a "CM" status (i.e., core melt or core damage). The fault trees provide system unavailability information to the event tree models as shown in Figure 1. The fault trees consist of components and other contributing factors that model the system functionality. Also included are factors that integrate human error and various types of equipment failure probability. As one can see in Figure 1, interactions with other support systems are also modeled. With this detailed model one can see how various parameters can be changed in the model to determine safety significance.

For example, instead of the normal service water pump being unavailable based on normal availability of the pump, the pump may be out of service based on maintenance activities. This would change the unavailability of the service water pump from .005 to 1.0 and therefore propagate through the analytical model calculation to ultimately impact the CDF. This same technique can be used to assess human reliability assumptions, changes to maintenance practices, operational changes, and design changes. GSU has used this concept to assess the safety impact on many decisions made at RBS.

As the PSA method of assessing plant safety became known to RBS plant staff, more requests to evaluate changes to the plant

and to resolve regulatory questions were received. A summary for some of the requests is presented in Table 1. These types of assessments provided valuable insights to plant management in addition to beneficial cost reduction by eliminating or reducing work activities on equipment that had little impact on plant safety. Also these insights were used to convince regulatory agencies that some required activities could be delayed without impacting plant safety.

## USES OF PRA

GSU began using PSA type evaluations in 1987 to support plant operation, maintenance activities, nuclear licensing regulatory issues, and engineering decision-making. The RBS plant specific PSA was developed using methods provided by NRC contractors<sup>2</sup>.

The PRA model of River Bend is a key portion of the severe accident evaluation process. The PRA model also provides an excellent tool for upper management decision-making<sup>3</sup>. With this detailed model, parameters can be changed in the model to determine safety significance. In addition, the model can determine the relative importance to core damage of various plant systems and components. These attributes allow PRA use when:

1. setting priorities for modifications
2. providing safety analyses for LERs, LCO extensions, waivers of compliance
3. assessing the risk associated with modifications, maintenance, or outage activities
4. responding to NRC safety concerns

Table 1 provides a summary of uses for the PRA at RBS. The first column in Table 1 provides a summary description of the task, the second column identifies the customer (i.e., major groups that are supported at RBS), the third column identifies the type of problem or situation which prompted the request and the fourth column identifies outage related work. As the RBS PRA becomes more mature, more integration into maintenance and technical specification support will take place.

The regulatory evaluations are typically performed to satisfy NRC questions and to support the Technical Specification questions.

## USING PRA FOR COMPLIANCE ISSUES

During a recent plant startup, it was determined that the reactor core isolation cooling (RCIC) system was inoperable and based on some estimates it would take more than a day to make operable. One of the reasons for RCIC during start-up is to mitigate the consequences of a control rod drop ensuring that a redundant safety related high pressure water source is available (i.e., in addition to high pressure core spray (HPCS)). Without RCIC operable, the plant was prohibited by Technical Specifications from entering the RUN mode. Once in the RUN mode, RCIC could be inoperable up to 14 days before shutdown actions are required. This is contingent on the availability of the high pressure core spray (HPCS) system. Therefore, the plant startup was placed on hold until the compliance issue could be resolved with the NRC to allow entrance to RUN mode without RCIC operable. Technical Specifications provide specific direction

to the operators so compliance to regulatory mandates can be maintained. As part of the technical justification for this authorization of compliance, a PSA was performed assuming RCIC inoperable. With RCIC operable, total CDF was  $2.07 \times 10^{-6}$ . With RCIC inoperable, total CDF was increased to  $9.6 \times 10^{-6}$ , or by a factor of 4.6. However, this was still an order of magnitude below the NRC safety goal of  $1.0 \times 10^{-4}$  for core damage events. Also, this change is within the uncertainty of PRA techniques. This PSA evaluation, along with other analyses, helped GSU obtain the requested waiver of compliance, which allowed plant startup to continue. Without this authorization, the plant could not start-up until the RCIC system became operable. Although the cost benefit would depend on the length of time required to have an operable RCIC system, the savings and contribution to safety are considered significant.

#### USING PRA TO PRIORITIZE

As part of River Bend Station's response to NRC Generic Letter (GL) 89-10, the PRA group was asked to evaluate priority of motor-operated valves (MOV) for inclusion in the MOV testing program. GL 89-10 stipulates that a large number of safety related MOVs required testing to ensure operability and conform to the original design basis. Approximately 200 safety related valves were identified to be tested. If the work was performed in a short time period, resources of maintenance and engineering would be overextended. Therefore, some way was necessary to identify the most important valves with respect to safety and inspect them first. As a result, sixty (60) MOVs were determined to be most important relative to plant safety. A list of these valves was developed and provided to Design Engineering for their use in preparing the MOV testing schedule. The benefit in this evaluation allowed resources to be allocated only to the most important activities with respect to safety and allowed the deferment of activities that had a minimal impact on plant safety thereby optimizing allocation of limited resources.

#### EXTENSION OF TECHNICAL SPECIFICATION LCO

During normal operations, one train of the heating, ventilation, and air-conditioning (HVAC) serving safety-related switchgear and battery rooms was declared inoperable. Plant Staff anticipated the need for a 24 hour extension to the 7-day Technical Specification Limiting Condition for Operations (LCO) governing this situation. A PSA was performed to support the LCO extension request. This analysis demonstrated that the 24-hour extension increased CDF from  $3.61 \times 10^{-6}$  to  $3.65 \times 10^{-6}$ , or an increase of only  $4 \times 10^{-8}$  per year. Therefore, the LCO extension had no significant impact on plant safety. This LCO extension allowed the plant to continue to operate without a shutdown thereby saving significant resources for GSU while keeping the plant safe and reliable.

#### USING PRA TO SAVE ON MAINTENANCE

Plant Engineering requested an evaluation of the potential plant maintenance impact of extending the calibration intervals to 54 months for a number of safety-related instruments. These instruments were divided into two groups; those that provide information or alarm functions only and those that provide signals

for automatic action. PSAs were performed on the instruments controlling automatic actions to demonstrate that this extension would have no significant impact on the core damage frequency at River Bend Station. For the instruments providing information or alarms, operating procedures were reviewed to determine their impact, if any, on the core damage frequency. Based on this evaluation, plant maintenance requirements were reduced for 28 instruments without impacting plant safety. This provides a reduction in maintenance cost for the life of the plant and a significant cost savings for GSU in reduced maintenance manpower requirements.

#### PRA SUPPORT FOR NRC MEETING

During normal plant operations, several valves which were identified in the Fire Hazard Analysis (for 10CFR50 Appendix R fire protection requirements) as being de-energized were discovered never to have been de-energized. Of the valves identified, one of the NRC's major concerns was the potential for a fire-induced interfacing system LOCA in the residual heat removal (RHR) shutdown suction line. A PSA was performed to determine the safety significance of being in this configuration. For fires in the control room the total core damage frequency was calculated to  $6.5 \times 10^{-10}$  per reactor year. Based on the fact that this CDF was well below the safety goal of  $10^{-4}$  for CDF and  $10^{-6}$  for a large release, it was concluded that the event had an insignificant impact on the health and safety of the public. A detailed presentation of this evaluation was provided at a NRC meeting. Figure 2 is typical of the information presented. This PSA helped convince the NRC that this event had little safety significance.

#### PRA EVALUATION OF TRANSFORMER OUT OF SERVICE

At the end of RBS Refueling Outage-2 (RF2), Engineering Analysis was requested to determine the impact on safety due to operating with one non-safety-related transformer out of service. The transformer in question is referred to as a preferred transformer 1RTX-XSR1A. A schematic of RBS electrical distribution is shown in Figure 3. During plant start-up, power to drive auxiliary equipment (i.e., service pump, feedwater pumps, condensate pumps, etc.) is taken from offsite (preferred power) through transformers 1RTX-XSR1A and 1RTX-XSR1B. When plant power generation is sufficient, the power to the auxiliaries is taken from normal station power through transformers 1STX-XNS1A and 1STX-XNS1B. During a loss of generator transient, the loads are shifted from normal station power to preferred power. If one of the preferred transformers is not available, the auxiliaries such as feedwater and service water would not have power, thereby not available for restoration of plant conditions to normal. Based on GSU's plant specific evaluation, this condition (i.e., start-up without preferred transformer) was determined to measurably impact safety. Although this transformer was not required to be in compliance with Technical Specifications, a PSA indicated plant operation without this transformer could increase the core damage frequency significantly. During this analysis, a comparison between the progression of the accident, under both the normal and current transformer configurations, to the required operator response was developed. This comparison is shown in Figure 4. This method of presentation allowed the differences to be easily noted. Figure 4 provided practical evidence to Operations that starting up without

a preferred transformer should be avoided. From these comparisons, Plant Staff determined that we should not start up with only one preferred transformer. Based on this PSA and the operator action comparison presented in Figure 4, plant start-up was delayed approximately two weeks while a replacement transformer was installed. Although plant start-up was allowed by Technical Specifications, GSU felt the prudent action was to delay start-up to minimize the chances for adverse operation of the plant.

## CONCLUSION

The PRA at River Bend Station was initially developed to address the requirements of NRC Generic Letter 88-20. However, in addition to fulfilling this regulatory role, the River Bend PRA has been utilized to support plant evolutions. At River Bend, the PRA represents an analytical tool capable of evaluating changes to plant design, operations and maintenance. Supporting requests for compliance issues and LCO extensions, quantifying the safety extensions of calibration intervals are a few examples of the changes which PSAs can evaluate. Such changes can have either positive or negative impacts on plant safety and reliability.

Integration of PRA techniques into day to day decision-making at the plant can lead to significant resource savings while ensuring that margins of safety are preserved.

## REFERENCES

1. Miller, J. S. and Cathey, N. G., "Implementation of an Individual Plant Examination at a Nuclear Utility." Paper presented at the American Nuclear Society 1989 Winter Meeting, San Francisco, Ca., November 26-30, 1989.
2. Drouin, M. T., et. al., Analysis of Core Damage Frequency from Internal Event: Methodology Guidelines, NUREG/CR-4550, Vol. 1, SAND86-2084, Sandia National Labs., Albuquerque, New Mexico (September 1987).
3. Miller, J. S. , Cathey, N. G., and Burton, J. L., "PRA Applications at an Operating Nuclear Utility," 91-JPG-NE-10. Paper presented at the International Power Generation Conference, San Diego, CA, October 6-10, 1991.

## PRA PLANT SUPPORT 1987 TO PRESENT

Table 1

	Customer	Request Type	Outage
1 Operations with ADS inoperable due to SVV compressors	Licensing/Plant Staff	Regulatory	
2 Drywell hydrogen igniter safety assessment	Licensing/EQ	Regulatory	RF3
3 Waiver of compliance on drywell airlock doors	Licensing/Plant Staff	Plant Support	RF3
4 Waiver of Compliance on Mode change with RCIC inoperable	Licensing/Plant Staff	Plant Support	RF3
5 Evaluation of HPCS Rosemount transmitters	Licensing/Plant Staff	Plant Support	RF3
6 Ranking of MOVs by risk	Design Engineering	Engineering	RF3
7 Estimate of the probability of SSE occurring in a 30 day period in support of RF3 control rod storage plans	Plant Staff	Plant Support	RF3
8 Probability of SSE or OBE	Licensing	Regulatory	RF3
9 Review of BWROG safety assessment on MOV isolation	Design Engineering	Engineering	RF3
10 Standby service water system single active failure analysis	Licensing	Regulatory	RF3
11 Reliability study for Olin 450 psig	GSU Industrial Marketing	Business Negotiations	
12 Asea Brown Boveri circuit breaker failures	Operations	Plant Support	
13 Impact of a short on DIV III bus while testing DIV III diesel generator	Design Engineering	Engineering	
14 Feedwater control - high level trip power supply	Design Engineering	Engineering	
15 24 hour extension on LCO due to 1HVC*AHU2A	Licensing	Regulatory	
16 Review of Scram 90-02	Operations	Plant Support	
17 Plant operations without auxiliary boiler	Design Engineering	Engineering	
18 Evaluation of 54 month instrument calibration interval	Maintenance	Plant Support	
19 Safety evaluation of proposed alternate electrical distribution alignment	Design Engineering	Engineering	
20 Analysis of the safety impact of having valve listed in the FHA as de-energized, energized	Design Engineering	Engineering	
21 Topaz inverter analysis	Plant Staff	Plant Support	
22 Temperature of a conduit near 1G33*MOVFO40	Design Engineering	Engineering	
23 NRC Augmented Inspection Team on interfacing system LOCA	Senior Management	Regulatory	
24 PSA of alternate shutdown cooling during mid-cycle 3 outage	Outage Management	Plant Support	
25 Effect of having a preferred station transformer out of service on core damage frequency	Senior Management	Plant support	
26 Probability of Anticipated Transient without Scram (ATWS) Events leading to Core Damage	Design Engineering	Engineering	
27 Risk/Benefit analysis of turbine stop/control valve testing with bypass	Design Engineering	Engineering	
28 Single failure scram analysis	ISEG	Engineering	

# PRA PLANT SUPPORT 1987 TO PRESENT

Table 1

	Customer	Request Type	Outage
29 Service Water Modification Risk Assessment	Outage Management	Plant Support	RF4
30 Analysis power loss to TSC/EOF	Emergency Planning	Plant Support	
31 1NNS-SWG1C alignment to 1NNS-SWG1A	Design Engineering	Engineering	
32 Containment airlock electrical penetrations	Design Engineering	Engineering	
33 HVC filter initiation	Operations	Plant Support	
34 Risk/Benefit Analysis of SWP and CNM Valves	Cost Systems	Business Decisions	
35 Seismic Margins	CEPCO	Regulatory	
36 Heat Removal Capability of Standby Cooling Tower	Operations	Plant Support	MCY4
37 1SWP*MOV507A Leakage	Plant Staff	Plant Support	MCY4
38 CRD HCU Cracks	Design Engineering	Plant Support	MCY4
39 Risk Analysis for SWP Piping	Design Engineering	Plant Support	RF4
40 Pre-R4 Closed Service Water Electrical Connections	Design Engineering	Engineering	RF4
41 Safety Assessment for Potter-Brumfield Relay LER	Licensing	Regulatory	
42 RCIC High Steam Flow Instrumentation	Plant Staff	Plant Support	
43 RF4 Freeze Seals	Design Engineering	Plant Support	RF4
44 CR 90-0554 PRA	Design Engineering	Plant Support	
45 Shutdown Risk Management	Outage Management	Plant Support	RF4
46 Misoriented Fuel Bundle HRA	Senior Management	Regulatory	RF4
47 Closed Service Water Risk Analyses	Design Engineering	Engineering	RF4
48 Hydrogen Mixing PRA and HRA	Senior Management	Regulatory	
49 Control Room Fire Hazards Analysis	Design Engineering	Regulatory	
50 HPCS Test Return Line Release	Licensing	Regulatory	





FIGURE 1



PROBABILITY OF PIPE RUPTURE = 1.0 E-2  
 FOR ECCS - SHORT TERM ASSUMED THAT LPCS IS FAILED, ONLY HPCS CAN RESPOND TO BREAK  
 TOTAL CORE DAMAGE FREQUENCY DUE TO FIRES IN MCR = 0.5 E-10 PER REACTOR-YEAR

FIGURE 2




FIGURE 3

# COMPARISON OF RIVER BEND TRANSIENT SEQUENCES

## NORMAL CONFIGURATION W/ PREFERRED E & B AVAILABLE

100% POWER	<p>SCRAM OCCURS FREQUENCY = 6/YR</p> <p>RESPONSE: LOSS OF NORMAL XFORMERS</p> <p>OPERATOR ACTIONS: AOP-1 REACTOR SCRAM AOP-2 MAIN TURB TRIP MUST ADDRESS CAUSE OF SCRAM</p> <p>STATUS: NORMAL SCRAM</p>	<p>LOSS OF PREFERRED-E AND FEEDWATER PROB = 1.0 X E-04</p> <p>RESPONSE: LOSS OF NPS-A LOSS OF FEEDWATER DEGRADED NSW DEGRADED CONDENSATE DEGRADED INSTR AIR DEGRADED RECIRC AUTO START SSW</p> <p>OPERATOR ACTIONS: AOP-3 AUTO ISOLATIONS AOP-6 COND/FW FAILURES AOP-10 LOSS OF ONE RPS AOP-11 LOSS OF RPCCW AOP-24 DECREASE IN RECIRC</p> <p>STATUS: N.O.U.E.</p>	<p>LOSS OF SSW PROB = 3.2 X E-03</p> <p>RESPONSE: LOSS OF ECCS (4-16 HOURS)</p> <p>OPERATOR ACTIONS: AOP-16 LOSS OF SSW</p> <p>STATUS: ALERT POTENTIAL UPGRADE TO S.A.E. HPCS AND RCIC FOR MAKEUP</p>	<p>OPERATOR RECOVERY ACTIONS FAIL PROB = 1 X E-02</p> <p>POTENTIAL RECOVERY ACTIONS: RESTORATION OF ROOM COOLING REALIGNMENT OF SSW CROSS TIE NPS A&amp;B BUSES RECOVERY OF HEAT SINK</p> <p>STATUS: HPCS AND RCIC FAIL ON ROOM COOLING SITE AREA EMERGENCY</p>
------------	---	--	---	---

## CONFIGURATION W/O NORMAL-B TRANSFORMER

100% POWER	<p>SCRAM OCCURS FREQUENCY = 6/YR</p> <p>RESPONSE: LOSS OF NPS-B DEGRADED FEEDWATER DEGRADED CONDENSATE DEGRADED INSTR AIR RECIRC PUMP TRIP DEGRADED NSW</p> <p>OPERATOR ACTIONS: AOP-1 REACTOR SCRAM AOP-2 MAIN TURB TRIP AOP-3 AUTO ISOLATIONS AOP-6 COND/FW FAILURES AOP-10 LOSS OF ONE RPS AOP-24 DECREASE IN RECIRC</p> <p>STATUS: MORE SEVERE THAN NORMAL SCRAM MORE SEVERE THAN IAS SCRAM</p>	<p>LOSS OF PREFERRED-E PROB = 3.5 X E-03</p> <p>RESPONSE: LOSS OF NPS-A LOSS OF FEEDWATER LOSS OF CONDENSATE LOSS OF INSTR AIR LOSS OF RECIRC LOSS OF NSW LOSS OF CB CHILL WATER</p> <p>OPERATOR ACTIONS: AOP-5 LOSS OF COND VAC AOP-9 LOSS OF NSW AOP-11 LOSS OF RPCCW</p> <p>STATUS: N.O.U.E. POTENTIAL UPGRADE TO ALERT MORE SEVERE THAN IAS SCRAM</p>	<p>LOSS OF SSW PROB = 3.2 X E-03</p> <p>RESPONSE: LOSS OF ECCS (4-16 HOURS)</p> <p>OPERATOR ACTIONS: AOP-16 LOSS OF SSW</p> <p>STATUS: ALERT POTENTIAL UPGRADE TO S.A.E. HPCS AND RCIC FOR MAKEUP</p> <p>CORE DAMAGE W/O RECOVERY</p>	<p>OPERATOR RECOVERY ACTIONS FAIL PROB = 1 X E-02</p> <p>POTENTIAL RECOVERY ACTIONS: RESTORATION OF ROOM COOLING REALIGNMENT OF SSW</p> <p>STATUS: HPCS AND RCIC FAIL ON LOSS OF RM COOLING CORE DAMAGE W/ RECOVERY SITE AREA EMERGENCY</p>	<p>SPECIAL RECOVERY ACTIONS FAIL PROB = 0.1</p> <p>RECOVERY OF NSW VIA GRANT SUB TIE-IN</p> <p>RECOVERY THROUGH FANCY POINT (LOW IMPACT)</p>
------------	---	---	---	---	--

FIGURE 4